



for a greener tomorrow



**MITSUBISHI
ELECTRIC**

Changes for the Better

FACTORY AUTOMATION

Miniature Circuit Breakers Residual Current Circuit Breakers Isolating Switches **DIN Series**



Breaking Through The




Introducing the DIN Series...

High-quality, high-performance circuit breakers suitable for household electrical distribution panels

DIN Series

INDEX

- **Features, Product Line-up and Points to Note** 3
 - Features and Product Line-up..... 3
 - Points to Note 4
- **Specifications** 5-6
- **Accessories** 7-8
- **Characteristics and Dimensions** 9
 - Miniature Circuit Breakers (MCB) 9-10
 - Residual Current Circuit Breakers (RCCB) 11
 - Residual Current Circuit Breakers with
Overcurrent Protection (RCBO) 12
 - Isolating Switches 13
- **Ordering Information** 14




Features

- (1) All models fully comply with IEC regulations
- (2) Units can be mounted on a standard 35mm IEC rail
- (3) Residual current circuit breakers use an original Mitsubishi Electric IC securing reliable earth-leakage protection
- (4) High current-limiting performance
- (5) Compliance with IP2X protection rating
- (6) All models are compatible with reverse connection
- (7) DC circuit-compatible model (BH-D10) added to product line-up

Product Line-up

Model type		No of poles (P)	Rating	Instantaneous tripping	Voltage (V)	Short-Circuit capacity (kA)	Compliance standard
MCB	BH-D6	1, 2, 3, 4(3+N)	0.5~63A	TYPE B, C, D	230/400AC	6	IEC60898-1
		1+N	0.5~40A	TYPE B, C	230AC		
	BH-D10	1, 2, 3, 4(3+N)	0.5~63A	TYPE B, C, D	230/400AC	10	IEC60898-1
	BH-D10 (For DC)	1	0.5~63A	TYPE B, C	125DC	10	IEC60898-2
					230/400AC	6	
		2			250DC	10	
BH-DN	1+N	6~20A	TYPE C	230AC	4.5	IEC60898-1	
RCCB	BV-D	2(1+N), 4(3+N)	25, 40, 63A	–	230/400AC	–	IEC61008-2-2
RCBO	BV-DN	1+N	6~40A	TYPE C	230AC	4.5	IEC61009-2-2
Isolating Switch	KB-D	1, 2, 3, 4(3+N)	32, 63, 80A	–	230/400AC	–	IEC60947-3

Explanation of Markings (Example Model Type : BH-D6)



Technical Specifications

Ambient temperature range	-10 ~ +40°C
Frequency	50/60Hz

DIN Series




Points to Note

1 Installation

Standard IEC35mm rail installation is possible.
Fix by attaching a slip stopper.

Fig-1



2 Connection

At the time of wire connection, fasten the terminal screws with the torque stated in the table below.

Fastening torque

Screw diameter	Fastening torque (N·m)	Model type
M5	1.7~2.5	BH-D6, BH-D10, BV-D, KB-D SHTA400-05DLS, SHTD048-05DLS
M4	1.0~1.5	BH-DN, BV-DN
M3.5	0.8~1.0	AL-05DLS, AX-05DLS, ALAX-05DLS AX2-05DLS

3 Opening, Closing and Tripping Operations

Move the handle up/down to turn power On/Off. Tripping operation refers to automatic opening (breaking) of circuits.

4 Earth-leakage Test

Earth-leakage test steps:

- (1) Move the handle to the On position under rated voltage.
- (2) Push the yellow test button.
- (3) At this time, the RCCB or RCBO must be tripped within the specified time.
- (4) The handle will move to the Off position.
- (5) The earth-leakage indication changes from white to red.

5 Withstand Voltage Test

(1) Withstand voltage test: The voltage applied to the main circuit during the withstand voltage test is 2,000VAC (effective for 1min). Do not conduct a withstand voltage tests using voltages exceeding 2,000VAC.

(2) Measurement of insulation resistance and withstand voltage test

Please note the following restrictions (① and ② below) that apply when using earth-leakage circuit breakers.

① Measuring insulation resistance:


- Do not use a 1000V insulation resistance tester. Please use a 500V insulation resistance tester.
- The "▲" marks in the table are based on minimum insulation resistance values.

② Testing withstand voltage: The "X" marks in the table below indicate that the test voltage is not to be applied to that model. (If a test voltage is accidentally applied to one of these models, do not reuse the product regardless of whether or not they were tripped.)


Measuring position		Test		Insulation resistance measurement		Withstand voltage test	
Handle position		ON	OFF	ON	OFF	ON	OFF
Between main circuit live part and ground		○	○	○	○	○	○
Between different poles	On line side	BV-D 2P BV-DN	▲	○	×	○	○
		BV-D 4P Between right pole (terminal symbol 6) and N pole Between poles other than above	▲	○	×	○	○
	On load side	BV-D 2P BV-DN	▲	▲	×	×	×
		BV-D 4P Between right pole (terminal symbol 6) and N pole Between poles other than above	○	○	○	○	○
Between terminals on line side and load side		—	○	—	○	—	○

6 Installation of Accessories (AX, AL, SHT)





(1) Installation



(2) Removal





Specifications

Type		MCB													
		BH-D6					BH-D10				BH-DN				
Image															
No. of poles [P]		1	2	3	4(3+N) ^{*1}	2(1+N) ^{*1}	1	2	3	4(3+N) ^{*1}	2 (1+N) ^{*1}				
Instantaneous tripping		Type B, C, D ^{*2}					Type B, C, D ^{*2}				Type C ^{*2}				
Rated insulation voltage U_i [V]		440					440				230				
Rated current I_n [A] at ambient temperature 30°C		0.5, 1, 1.6, 2, 3, 4, 6, 10, 13, 16, 20, 25, 32, 40, 50, 63					0.5, 1, 1.6, 2, 3, 4, 6, 10, 13, 16, 20, 25, 32, 40				0.5, 1, 1.6, 2, 3, 4, 6, 10, 13, 16, 20, 25, 32, 40, 50, 63				
Rated short-circuit capacity [kA]	IEC60898-1 GB10963.1 (Icn)	AC	230V	6	–	6	10	–	–	–	4.5				
			230/400V	6	–	–	10	–	–	–	–				
			400V	–	6	–	–	10	–	–	–				
Number of operating cycles		Without current		8,000					10,000				20,000		
		With current		8,000					10,000				20,000		
Dimensions [mm]			a	18	36	54	72	36	18	36	54	72	18		
			b	87					87				88		
			c	44					44				44		
			ca	70					70				70		
			Type of overcurrent release		Thermal-magnetic					Thermal-magnetic				Thermal-magnetic	
Mounting		IEC35mm rail					IEC35mm rail				IEC35mm rail				
Applicable wire size		1 to 25mm ²					1 to 25mm ²				1 to 10mm ²				
Mass [kg]		0.15	0.3	0.45	0.55	0.25	0.15	0.3	0.45	0.55	0.12				
Accessories (optional)	Alarm switch (AL)		○					○				–			
	Auxiliary switch (AX)		○					○				–			
	Shunt trip (SHT)		○					○				–			
Terminal connection		Solderless					Solderless				Solderless				
Based on standard		IEC60898-1					IEC60898-1				IEC60898-1				
CE marking		EN60898-1 : Self-declaration					EN60898-1 : Self-declaration				EN60898-1 : Self-declaration				
CCC		GB10963.1					GB10963.1				GB10963.1				

*1: N pole is a switched neutral pole (without overcurrent release device).



*2: Type B: (3 In <, ≤ 5 In), Type C: (5 In <, ≤ 10 In), Type D: (10 In <, ≤ 20 In)

Type		For DC			
		BH-D10			
Image					
No. of poles [P]		1	2		
Instantaneous tripping		Type B, C ^{*3}			
Rated insulation voltage U_i [V]		250			
Rated current I_n [A] at ambient temperature 30°C		0.5, 1, 1.6, 2, 3, 4, 6, 10, 13, 16, 20, 25, 32, 40, 50, 63			
Rated short-circuit capacity [kA]	IEC60898-2 GB10963.2 (Icn)	DC	125V	10	–
			250V	–	10
		AC	230/400V	6	–
			400V	–	6
Number of operating cycles		Without current		8,000	
		With current		4,000	
Dimensions [mm]			a	18	36
			b	87	
			c	44	
			ca	70	
			Type of overcurrent release		Thermal-magnetic
Mounting		IEC35mm rail			
Applicable wire size		1 to 25mm ²			
Mass [kg]		0.15	0.3		
Accessories (optional)	Alarm switch (AL)		○		
	Auxiliary switch (AX)		○		
	Shunt trip (SHT)		○		
Terminal connection		Solderless			
Based on standard		IEC60898-2			
CE marking		EN60898-2 : Self-declaration			
CCC		GB10963.2			

*3: Type B: (4 In <, ≤ 7 In), Type C: (7 In <, ≤ 15 In) for DC
Type B: (3 In <, ≤ 5 In), Type C: (5 In <, ≤ 10 In) for AC





Specifications



		RCCB	
Type		BV-D	
Image			
No. of poles [P]		$2(1+N)^{-1}$	$4(3+N)^{-1+3}$
Rated current [A] at ambient temperature 30°C		25, 40, 63	
Rated voltage [VAC]		230	230/400
Rated current sensitivity $I\Delta n$ [mA]		30, 300	
Max. operating time at $5I\Delta n$ [s]		0.04	
Pulsating current sensitivity		Type AC	
Rated conditional short-circuit current [kA]		6	
Dimensions [mm]		a	36
		b	85
		c	44
		ca	70
Mass [kg]		0.2	0.35
Rated making and breaking capacity I_m [A]		500(In 25,40A), 630(In63A)	
Rated conditional short-circuit current I_{nc} [kA]		6	
Rated residual making and breaking capacity $I_{\Delta m}$ [A]		500(In 25,40A), 630(In63A)	
Rated conditional residual short-circuit current $I_{\Delta c}$ [kA]		6	
Number of operating cycles	Without current	8,000	
	With current	8,000	
Type of overcurrent release		-	
Mounting		IEC35mm rail	
Applicable wire size		1 to 25mm ²	
Terminal connection		Solderless	
Based on standard		IEC61008-2-2	
CE marking		EN61008-2-2 : Self-declaration	
CCC		GB16916.22	

*1: N pole is a switched neutral pole (without overcurrent release device).

*2: Type C: (5 In <, ≤ 10 In)

*3: For use to three phase 4-wire type. When using, it be sure to connect the neutral wire to the neutral phase. Not available for use to three phase 3-wire type.

		RCBO	
Type		BV-DN	
Image			
No. of poles [P]		$2(1+N)^{-1}$	
Rated current [A] at ambient temperature 30°C		6, 10, 16, 20, 25, 32, 40	
Rated voltage [VAC]		230	
Rated current sensitivity $I\Delta n$ [mA]		30, 100, 300	
Max. operating time at $5I\Delta n$ [s]		0.04	
Pulsating current sensitivity		Type AC	
Breaking capacity [kA] sym. (IEC 61009)		4.5	
Tripping characteristics		Type C ²	
Dimensions [mm]		a	36
		b	88
		c	44
		ca	70
Mass [kg]		0.19	
Automatic tripping device		Thermal, magnetic	
Number of operating cycles	Without current	20,000	
	With current	20,000 (In 6,10,16,20A) 15,000 (In 25A) 10,000 (In 32,40A)	
Type of overcurrent release		Thermal-magnetic	
Mounting		IEC35mm rail	
Applicable wire size		1 to 16mm ²	
Terminal connection		Solderless	
Based on standard		IEC61009-2-2	
CE marking		EN61009-2-2 : Self-declaration	
CCC		GB16917.22	

		Isolating switch			
Type		KB-D			
Image					
No. of poles [P]		1	2	3	4(3+N)
Utilization category		AC-22A			
Rated current [A] at ambient temperature 30°C		32, 63, 80			
Rated voltage [VAC]		230	400		
Short time withstand current [A]		$20 \times I_n$, 1s			
Short-circuit making capacity [A]		$20 \times I_n$			
Dimensions [mm]		a	18	36	54
		b	87		
		c	44		
		ca	70		
Mass [kg]		0.09	0.18	0.27	0.36
Optional accessories		Insulating barrier	—	1 pc.	2 pcs.
Number of operating cycles	Without current	20,000			
	With current	3,000			
Mounting		IEC35mm rail			
Applicable wire size		1 to 25mm ²			
Terminal connection		Solderless			
Based on standard		IEC60947-3			
CE marking		EN60947-3 : Self-declaration			
CCC		GB14048.3			

Accessories

Functions of Accessories

Internal accessory	Function
AL Alarm switch	Electrically indicates the trip status of the circuit breaker.
AX Auxiliary switch	Electrically indicates the On/Off status of the circuit breaker.
SHT Shunt trip	Electrically trips the circuit breaker from a remote location. Permissible working voltages are 70 to 110% of the AC rated voltage or 70 to 125% of the DC rated voltage.

Equipping of Accessories

Accessory \ Model name	BH-D6	BH-D10	BH-DN, BV-DN, KB-D, BV-D
AL	○	○	-
AX	○	○	
SHT	○	○	

○: Accessory equipped

–: Accessory not equipped

Specifications

Type		AL	AX	AL+AX	AX+AX
		AL-05DLS	AX-05DLS	ALAX-05DLS	AX2-05DLS
Contact	Configuration	1C	1C	2C	2C
	Contact capacity	400VAC, 2A	230VAC, 5A	120VDC, 0.4A	48VDC, 1.5A
Function	Line	–	–	AX	AX
	Load	AL	AX	AL	AX
Connection		Clamp terminal			
Compliance standard		IEC60947-5-1			

Type	SHT	
	SHTA400-05DLS	SHTD048-05DLS
Cut-off switch	Equipped	
Voltage	110-400VAC	24-48VDC
Input power requirement	110VAC 60VA 230VAC 250VA 400VAC 750VA	24VDC 75VA 48VDC 300VA
Operating time [ms]	<20	
Connection	Solderless terminal	
Compliance standard	IEC60947-2	

* Secure a sufficient input power supply so that the voltage will not drop below the permissible lower working voltage (70% of the lowest rated voltage).

* The operating time denotes the time from when the rated voltage is applied to SHT until the time the main contact of the breaker starts to open.


Accessories

Combinations of Accessories


Accessory connection combinations	AL	
	AX	
	2AX	
	ALAX	
	SHT	
	AX+SHT	
	AL+SHT	
	2AX+SHT	
	ALAX+SHT	



Outer Dimensions



Connection of Line and Load Side



Characteristics and Dimensions

Miniature Circuit Breakers




BH-D6 BH-D10



Type		BH-D6					BH-D10				BH-D10 (For DC)	
No. of poles [P]		1	2	3	4(3+N) ^{*1}	2(1+N) ^{*1}	1	2	3	4(3+N) ^{*1}	1	2
Instantaneous tripping		Type B, C, D				Type B, C	Type B, C, D				Type B, C	
Rated insulation voltage U_i [V]		440					440				250	
Rated current I_n [A] at ambient temperature 30°C		0.5, 1, 1.6, 2, 3, 4, 6, 10, 13, 16, 20, 25, 32, 40, 50, 63				0.5, 1, 1.6, 2, 3, 4, 6, 10, 13, 16, 20, 25, 32, 40	0.5, 1, 1.6, 2, 3, 4, 6, 10, 13, 16, 20, 25, 32, 40, 50, 63				0.5, 1, 1.6, 2, 3, 4, 6, 10, 13, 16, 20, 25, 32, 40, 50, 63	
Rated short-circuit capacity [kA]	IEC60898-1 GB10963.1 (lcn)	AC	230V	6	—	6	10	—	—	—	—	—
			230/400V	6	—	—	10	—	—	—	—	—
			400V	—	6	—	—	10	—	—	—	—
	IEC60898-2 GB10963.2 (lcn)	DC	125V	—	—	—	—	—	—	10	—	—
			250V	—	—	—	—	—	—	—	10	—
		AC	230/400V	—	—	—	—	—	—	6	—	—
	400V	—	—	—	—	—	—	—	6	—		


*1: N pole is a switched neutral pole (without overcurrent release device).

Operating Characteristics




* When using BH-D10 (for DC) in AC circuit, characteristic curve of BH-D10 (Type B, C) for AC is applied.

Outer Dimensions



Ambient Compensation Curve



* In case of installing breakers side by side, reduce the passing current to under 80% of the rated current.

Characteristics and Dimensions

Miniature Circuit Breakers (MCB)


BH-DN




Type		BH-DN	
No. of poles [P]		2 (1+N) ^{*1}	
Instantaneous tripping		Type C	
Rated insulation voltage U_i [V]		230	
Rated current I_n [A] at ambient temperature 30°C		6, 10, 16, 20	
Rated short-circuit capacity [kA]	IEC60898-1 GB10963.1 (Icn)	AC	230V
4.5			

*1: N pole is a switched neutral pole (without overcurrent release device).


Operating Characteristics



Outer Dimensions



Ambient Compensation Curve



* In case of installing breakers side by side, reduce the passing current to under 80% of the rated current.

Characteristics and Dimensions

Residual Current Circuit Breakers (RCCB)

BV-D




Type	BV-D	
No. of poles [P]	$2(1+N)^{*1}$	$4(3+N)^{*1-2}$
Rated operational voltage U_e [AC V]	230	230/400
Rated current I_n [A] at ambient temperature 30°C	25, 40, 63	
Rated current sensitivity $I\Delta n$ [mA]	30, 300	
Max. operating time at $5I\Delta n$ [s]	0.04	
Pulsating current sensitivity	Type AC	
Residual operation	Dependent on line voltage	
Rated making and breaking capacity I_m [A]	500(In 25,40A) 630(In63A)	
Rated conditional short-circuit current I_{nc} [kA]	6	
Rated residual making and breaking capacity $I_{\Delta m}$ [A]	500(In 25,40A) 630(In63A)	
Rated conditional residual short-circuit current $I_{\Delta c}$ [kA]	6	


*1: N pole is a switched neutral pole (without overcurrent release device).

*2: For use to three phase 4-wire type. When using, it be sure to connect the neutral wire to the neutral phase. Not available for use to three phase 3-wire type.

Operating Characteristics



Outer Dimensions



Characteristics and Dimensions

Residual Current Circuit Breakers with Overcurrent Protection (RCBO)



BV-DN




Type		BV-DN		
No. of poles [P]		2(1+N) ^{*1}		
Rated operational voltage U_e [VAC]		230		
Rated current I_n [A] at ambient temperature 30°C		6, 10, 16, 20, 25, 32, 40		
Instantaneous tripping		Type C		
Rated current sensitivity $I_{\Delta n}$ [mA]		30, 100, 300		
Max. operating time at $5I_{\Delta n}$ [s]		0.04		
Pulsating current sensitivity		Type AC		
Residual operation		Dependent on line voltage		
Rated short-circuit capacity [kA]	IEC61009-1 GB16917.1 (Icn)	AC	230V	4.5

*1: N pole is a switched neutral pole (without overcurrent release device).


Operating Characteristics



Outer Dimensions



Ambient Compensation Curve



* In case of installing breakers side by side, reduce the passing current to under 80% of the rated current.

Characteristics and Dimensions


Isolating switches

KB-D



Type	KB-D			
No. of poles [P]	1	2	3	4(3+N)
Utilization category	AC22A class			
Rated insulation voltage U_i [V]	250	440		
Rated voltage U_e [VAC]	230	400		
Rated current I_n [A] at ambient temperature 30°C	32, 63, 80			
Short-time withstand current [A]	20× I_n , 1s			
Short-time making current [A]	20× I_n			

Outer Dimensions



Ordering Information

Please specify items with

Type name	Number of poles	Rated current	Operating characteristics	Rated voltage	Quantity
BH-D6	1P	6A	Type C	DC	12
↓	↓	↓	↓	↓	
BH-D6 BH-D10	1P, 2P, 3P, 4P, 1P+N	0.5, 1, 1.6, 2, 3, 4, 6, 10, 13, 16, 20, 25, 32, 40, 50, 63A	Type B Type C Type D	Specify DC voltage when used in DC circuit	

Type name	Number of poles	Rated current	Operating characteristics	Quantity
BH-DN	1P+N	6A	Type C	12
		↓		
		6, 10, 16, 20A		

Type name	Number of poles	Rated current	Quantity
KB-D	1P	32A	12
	↓	↓	
	1P, 2P, 3P, 4P	32, 63, 80A	

Type name	Number of poles	Rated current	Rated sensitivity current	Quantity
BV-D	2P	25A	30mA	6
	↓	↓	↓	
	2P, 4P	25, 40, 63A	30, 300mA	

Type name	Number of poles	Rated current	Rated sensitivity current	Operating characteristics	Quantity
BV-DN	1P+N	6A	30mA	Type C	6
		↓	↓		
		6, 10, 16, 20, 25, 32, 40A	30, 100, 300mA		

Information from Fukuyama Works

<http://www.MitsubishiElectric.co.jp/haisei/lvs/>



Four Key Features

- ① Product Information
- ② Downloads
- ③ News
- ④ Support

MINIATURE CIRCUIT BREAKERS, RESIDUAL CURRENT CIRCUIT BREAKERS & ISOLATING SWITCHES

Sales Network

Country / Region	Corporation Name	Address	Telephone
Australia	Mitsubishi Electric Australia Pty. Ltd.	348 Victoria Road, Rydalmere, N.S.W. 2116, Australia	+61-2-9684-7777
Bangladesh	PROGRESSIVE TRADING CORPORATION	Haque Tower, 2nd floor, 610/11, Jubilee Road, Chittagong, Bangladesh	+880-31-624-307
	ELECTRO MECH AUTOMATION & ENGINEERING LTD.	Purana Paltan Lane, (VIP Road), Rokeya Mansion(6th floor), Room#702, Dhaka-1000, Bangladesh	+880-28-321-791
Belarus	Tehnikon	Oktyabrskaya 19, Off. 705, BY-220030 Minsk, Belarus	+375(0)17210 46 26
Belgium	Koning & Hartman B.V.	Woluwelaan 31, BE-1800 Vilvoorde, Belgium	+32(0)2/2570240
Cambodia	DHINIMEX CO.,LTD	#245, St. Tep Phan, Phnom Penh, Cambodia	+855-23-997-725
Chile	Rhona S.A.	Vte. Agua Santa 4211 Casilla 30-D (P.O. Box) Vina del Mar, Chile	+56-32-2-320-600
China	Mitsubishi Electric Automation (China) Ltd.	Mitsubishi Electric Automation Building, No.1386 Hongqiao Road, Shanghai, 200336	+86-21-2322-3030
	Mitsubishi Electric Automation (China) Ltd. Beijing Branch	9/F, Office Tower1 Henderson Centre 18 Jianguomennei Dajie DongCheng district Beijing 100005	+86-10-6518-8830
	Mitsubishi Electric Automation (China) Ltd. ShenZhen Branch	Room 2512--2516, Great China International Exchange Square, Zhen Tian Rd.S., Futian District, Shenzhen, 518034	+86-755-2399-8272
	Mitsubishi Electric Automation (China) Ltd. GuangZhou Branch	Room 1609, North Tower, The Hub Center, No.1068, Xing Gang East Road, Haizhu District, Guang Zhou, China 510335	+86-20-8923-6730
	Mitsubishi Electric Automation (China) Ltd. ChengDu Branch	Block B, Room 407-408, Shangri-La Center Office Building, No.9 BinJiang East Road, Chengdu, China 610021	+86-28-8446-8030
	Mitsubishi Electric Automation (Hong Kong) Ltd.	20/F., Cityplaza One, 111 King's Road, Taikoo shing, Hong Kong	+852-2510-0555
Colombia	Proelectric Representaciones S.A.	Carrera 42 # 75-367 Bod 109 Itagui Colombia	+57-4-4441284
Czech Republic	AUTOCONT CONTROL SYSTEMS S.R.O	Technologická 374/6, CZ-708 00 Ostrava - Pustkovec	+420 595 691 150
Denmark	BEIJER ELECTRONICS A/S	LYKKEGARDSVEJ 17, DK-4000 ROSKILDE	+45(0)4675 76 66
Egypt	Cairo Electrical Group	9, Rostoum St. Garden City P.O. Box 165-11516 Maglis El-Shaab, Cairo - Egypt	+20-2-27961337
France	Mitsubishi Electric Europe B.V.	25, Boulevard des Bouvets, F-92741 Nanterre Cedex	+33(0)1/55 68 55 68
Germany	Mitsubishi Electric Europe B.V.	Gothaer Str. 8, 40880 Ratingen , Germany	+49(0) 2102 486-0
Greece	KALAMARAKIS - SAPOUNAS S.A.	IONIAS & NEROMILOU STR., CHAMOMILOS ACHARNES, ATHENS, 13678 Greece	+30-2102 406000
	UTEKO	5, MAVROGENOUS STR., 18542 PIRAEUS, Greece	+30-211-1206-900
Hungary	Meltrade Ltd.	Fertő utca 14, HU-1107 Budapest, Hungary	+36(0)1-431-9726
India	Mitsubishi Electric India Private Limited	2nd Floor, Tower A&B, Cyber Greens, DLF Cyber City, DLF Phase-III, Gurgaon - 122 022 Haryana, India	+91-124-4630300
Indonesia	P. T. Sahabat Indonesia	P.O.Box 5045 Kawasan Industri Perdagangan, Jakarta, Indonesia	+62-(0)21-6610651-9
Ireland	Mitsubishi Electric Europe B.V.	Westgate Business Park, Ballymoun, IRL-Dublin 24, Ireland	+353(0)1-4198800
Israel	Gino Industries Ltd.	26, Ophir Street IL-32235 Haifa, Israel	+972(0)4-867-0656
Italy	Mitsubishi Electric Europe B.V.	Viale Colleone 7, I-20041 Agrate Brianza (MI), Italy	+39 039-60531
Kazakhstan	Kazpromavtomatika	ul. Zhambyla 28, KAZ - 100017 Karaganda	+7-7212-501000
Korea	Mitsubishi Electric Automation Korea Co., Ltd	9F Gangseo Hangang xi-tower, 401 Yangcheon-ro, Gangseo-gu, Seoul 07528 Korea	+82-2-3660-9572
Laos	AROUNKIT CORPORATION IMPORT-EXPORT SOLE CO.,LTD	SAPHANMO VILLAGE, SAYSETHA DISTRICT, VIENTIANE CAPITAL, LAOS	+856-20-415899
Lebanon	Comptoir d'Electricite Generale-Liban	Cebaco Center - Block A Autostrade Dora, P.O. Box 11-2597 Beirut - Lebanon	+961-1-240445
Lithuania	Rifas UAB	Tinklu 29A, LT-5300 Panevezys, Lithuania	+370(0)45-582-728
Malaysia	Mittrich Sdn Bhd	No. 5 Jalan Pemberita U1/49, Temasya Industrial Park, Glenmarie 40150 Shah Alam, Selangor, Malaysia	+603-5569-3748
Malta	ALFATRADE LTD	99 PAOLA HILL, PAOLA PLA 1702, Malta	+356(0)21-697-816
Marocco	SCHIELE MAROC	KM 7,2 NOUVELLE ROUTE DE RABAT AIN SEBAA, 20600 Casablanca, Marocco	+212 661 45 15 96
Myanmar	Peace Myanmar Electric Co.,Ltd.	NO137/139 Botahtaung Pagoda Road, Botahtaung Town Ship 11161, Yangon, Myanmar	+95-(0)1-202589
Nepal	Watt&Volt House	KHA 2-65, Volt House Dillibazar Post Box: 2108, Kathmandu, Nepal	+977-1-4411330
Netherlands	Imtech Marine & Offshore B.V.	Sluisjesdijk 155, NL-3087 AG Rotterdam, Netherlands	+31(0)10-487-19 11
North America	Mitsubishi Electric Automation, Inc.	500 Corporate Woods Parkway, Vernon Hills, IL 60061 USA	+847-478-2100
Norway	Scanelec AS	Leivikasen 43B, NO-5179 Godvik, Norway	+47(0)55-506000
Middle East Arab Countries & Cyprus	Comptoir d'Electricite Generale-International-S.A.L.	Cebaco Center - Block A Autostrade Dora P.O. Box 11-1314 Beirut - Lebanon	+961-1-240430
Pakistan	Prince Electric Co.	2-P, GULBERG II, LAHORE - 54660 PAKISTAN	+92-(0)42-35752323 +92-(0)42-35753373
	AL-KAMAL GROUP	Office No. 7 & 8, 1st Floor, Barkat Ali Khan Center, 101 Circular Road, Lahore. Pakistan	+92-(0)42-37631632
Philippines	Edison Electric Integrated, Inc.	24th Fl. Galleria Corporate Center, Edsa Cr. Ortigas Ave., Quezon City Metro Manila, Philippines	+63-(0)2-634-8691
Poland	Mitsubishi Electric Europe B.V. Polish Branch	Krakowska 50, 32-083 Balice, Poland	+48(0)12 630 47 00
Republic of Moldova	Intehsis SRL	bld. Traian 23/1, MD-2060 Kishinev, Moldova	+373(0)22-66-4242
Romania	Sirius Trading & Services SRL	RO-060841 Bucurestii, Sector 6 Aleea Lacu! Morii Nr. 3	+40-(0)21-430-40-06
Russia	Mitsubishi Electric Europe B.V. Moscow Branch	52, bld. 3 Kosmodamienskaya Nab, 115054, Moscow, Russia	+7 495 721-2070
Saudi Arabia	Center of Electrical Goods	Al-Shuwayer St. Side way of Salahuddin Al-Ayoubi St. P.O. Box 15955 Riyadh 11454 - Saudi Arabia	+966-1-4770149
Singapore	Mitsubishi Electric Asia Pte. Ltd.	307 Alexandra Road, Mitsubishi Electric Building, Singapore 159943	+65-6473-2308
Slovakia	PROCONT, Presov	Kupelna 1/, SK - 08001 Presov, Slovakia	+421(0)51-7580 611
	SIMAP	Jana Derku 1671, SK - 91101 Trencin, Slovakia	+ 421(0)32 743 04 72
Slovenia	Inea RBT d.o.o.	Stegne 11, SI-1000 Ljubljana, Slovenia	+386(0)1-513-8116
South Africa	CBI-electric: low voltage	Private Bag 2016, ZA-1600 Isando Gauteng, South Africa	+27-(0)11-9282000
Spain	Mitsubishi Electric Europe B.V. Spanish Branch	Carretera de Rubi 76-80, E-08190 Sant Cugat del Vallés (Barcelona), Spain	+34(0)93-565-3131
Sweden	Euro Energy Components AB	Järnvägsgatan 36, S-434 24 Kungsbacka, Sweden	+46(0)300-690040
Switzerland	TriElec AG	Muehlientalstrasse 136, CH-8201 Schaffhausen	+41-(0)52-6258425
Taiwan	Setsuyo Enterprise Co., Ltd	5th Fl., No.105, Wu Kung 3rd, Wu-Ku Hsiang, Taipei, Taiwan, R.O.C.	+886-(0)2-2298-8889
Thailand	United Trading & Import Co., Ltd.	77/12 Bamrungmuang Road, Klong Mahanak Pomprab Bangkok Thailand	+66-223-4220-3
Tunisia	MOTRA Electric	3, Résidence Imen, Avenue des Martyrs Mourouj III, 2074 - El Mourouj III Ben Arous, Tunisia	+216-71 474 599
Turkey	GTS	Bayraktar Bulvarı Nutuk Sok. No:5, Posta Kutusu34384, TR-34775 Yukan Dudullu-Uemraniye, Istanbul, Turkey	+90(0)216 526 3990
United Kingdom	Mitsubishi Electric Europe B.V.	Travellers Lane, UK-Hatfield, Herts. AL10 8XB, United Kingdom	+44(0)1707-276100
Uruguay	Fierro Vignoli S.A.	Avda. Uruguay 1274 Montevideo Uruguay	+598-2-902-0808
Venezuela	Adesco S.A.	Calle 7 La Urbina Edificio Los Robles Locales C y D Planta Baja, Caracas - Venezuela	+58-212-241-9952
Vietnam	Mitsubishi Electric Vietnam Co., Ltd. Head Office	Unit01-04, 10th Floor, Vincom Center, 72 Le Thanh Ton Street, District 1, Ho Chi Minh City, Vietnam	+84-28-3910-5945
	Mitsubishi Electric Vietnam Co., Ltd. Hanoi Branch	24th Floor, Handico Tower, Pham Hung Road, khu do thi moi Me Tri Ha, Nam Tu Liem District, Hanoi City, Vietnam	+84-24-3937-8075

For Safety : Please read the instruction manual carefully before using the products in this catalog.
Wiring and connection must be done by the person have a specialized knowledge of electric construction and wiring.



for a greener tomorrow

Eco Changes is the Mitsubishi Electric Group's environmental statement, and expresses the Group's stance on environmental management. Through a wide range of businesses, we are helping contribute to the realization of a sustainable society.



MITSUBISHI ELECTRIC CORPORATION

HEAD OFFICE: TOKYO BUILDING, 2-7-3, MARUNOUCHI, CHIYODA-KU, TOKYO 100-8310, JAPAN